



Michael C. Newbury
Chief of Department
Thomas D'Eon
Deputy Fire Chief

Saugus Fire Department

27 Hamilton Street
SAUGUS, MASSACHUSETTS 01906
Phone: (781) 941-1170 • Fax: (781) 231-4158



Captain Jim Hughes
Fire Prevention
Captain Scott Phelan
Fire Prevention

UNVENTED PROPANE OR NATURAL GAS-FIRED SPACE HEATERS

- Permit Obtained
- Manufacturer's instructions available
- Has oxygen depletion safety (ODS) shutoff system
- Proper clearances per manufacturer's instructions
- Installation is permanent, with permanently piped fuel supply
- Not in bedroom or bathroom
- BTU is 40,000 or less
- Carbon monoxide detector is present in room
- Smoke detectors present per 780 CMR
- Primary heat source, permanently installed. **Primary heat shall not include fireplaces or wood stoves.**

"SMOKE DETECTORS SAVE LIVES"